



Government of Karnataka



RURAL DRINKING WATER & SANITATION DEPARTMENT

Office of the Asst Executive Engineer

Rural Drinking Water & Sanitation Department, sub- Division

Chandra Reddy Complex, kuvempu Circle, Bangarpet-563114

Email: Aeerdwsd.bgpt@gmail.com

TEST REPORT

Name&Address Principal Jeevan Pragathi Golden International school Nallaguttahalli(V) Kethaganahalli(Gp) Bangarpet(T) Kolar(D)				Report date: 13/07/2026	
				Report Number: JULY0015	
				Reference: Sample receipt Form	
				Sample receipt date: 10/07/2026	
				Sample code: BGPT26JUL0015	
				Date of Sample collection: 10/07/2026	
				Analysis start date : 10/07/2026	
				Analysis completion date: 10/07/2026	
Sample collection protocol: APHA METHOD				Sample quantity: 1 Litre	
Sample Particulars: BOREWELL WATER					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colorless Clear Liquid					
1.	pH Value @ 25.1°C	7.08	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance, r5µS/cm@ Temp 25.1°C	927	—	—	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	2.0	5	15	IS 3025 (Part-4) : 2021
6.	Turbidity, NTU	0.4	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids @ 180°C, mg/l	578	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	113	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	446	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	76	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	61	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	59	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	28.8	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.9	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	26	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: all the above tested parameters with in the permissible limit.					
Analysed by:			Verified by:		
Analyst			Assistant Executive Engineer		

Note: ಈ ಸಾಂಯವು ತಪ್ಪು ಇಲ್ಲವೆಂದು ನಿರ್ದಿಷ್ಟಪಡಿಸಲಾಗಿದೆ. ಇದರಲ್ಲಿ ದೋಷವು ಇರುವುದಿಲ್ಲ ಎಂದು ನಿರ್ದಿಷ್ಟಪಡಿಸಲಾಗಿದೆ. ಬಿಡಿ ಗಾಂವುಗಳಿಗೆ + 563 114.

The above results relate only to the sample tested.

- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Rural Drinking Water & Sanitation Department
Sub-Division Bangarpet - 563114,



Government of Karnataka

RURAL DRINKING WATER & SANITATION DEPARTMENT

Office of the Asst Executive Engineer

Rural Drinking Water & Sanitation Department, sub- Division
Chandra Reddy Complex, kuvempu Circle, Bangarpet-563114

Email: Aeerdwsd.bgpt@gmail.com



TEST REPORT

Name&Address Principal Jeevan Pragathi Golden International school Nallaguttahalli(V) Kethaganahalli(Gp) Bangarpet(T) Kolar(D)			Report date: 13/07/2026		
			Report Number: JULY0014		
			Reference: Sample receipt Form		
			Sample receipt date: 10/07/2026		
			Sample code: BGPT26JUL0014		
			Date of Sample collection: 10/07/2026		
			Analysis start date : 10/07/2026		
			Analysis completion date: 10/07/2026		
Sample collection protocol: APHA METHOD			Sample quantity: 1 Litre		
Sample Particulars: WPP WATER					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colorless Clear Liquid					
1.	pH Value @ 25.1°C	6.68	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance, 25µS/cm@ Temp 25.1°C	88	—	—	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	0.5	5	15	IS 3025 (Part-4) : 2021
6.	Turbidity, NTU	<1	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids @ 180°C, mg/l	55	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	15	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	23	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	6.0	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	21	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	2.7	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.02	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	2.0	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: all the above tested parameters with in the Acceptable limit.					

Analysed by:
Analyst

Verified by:

Assistant Executive Engineer

Rural Drinking Water & Sanitation Department
Sub-Division Bangarpet - 563114

ರೂರಲ್ ಡ್ರಿಂಗ್ ವಾಟರ್ ಸ್ಯಾನಿಟೇಷನ್ ಡಿಪಾರ್ಟ್‌ಮೆಂಟ್
RDWSD/WQMSP/TeR/01
ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ, ಕುಲೆಂಪು ಸಿರ್ಕಲ್, ಬಂಗರಪೆಟ್ - 563114.

The above results relate only to the sample tested.

- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 347

Dated: 13/07/2026

It is certified that an inspection team headed by: **N.Ananda.Kumar(Assistant Executive Engineer)**
Anil Kumar K.M (Chemist)

(Name of Officers with designation) from Rural drinking and water sanitation Department. PHED inspected the **Jeevan Pragathi Golden International School Nallaguttahalli (V) Kethaganahalli(Gp) Bangarpet taluk** on10/07/2026. (date of inspection) and on the basis of Water Test Report (Attached) bearing no. BGPTJULY 0014& BGPT JULY 0015 dated..10/07/2026 of Taluk Level Water Testing Laboratory Bangarpet.. (PHED(Lab) certified that The Jeevan Pragathi Golden International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt

This certificate is valid till 10/01/2027

Signature with Seal:-

N. Ananda Kumar
Assistant Executive Engineer
Rural Drinking Water & Sanitation Department
Sub-Division Bangarpet - 563114.

Name: N.AnandaKumar

Designation: Assistant Executive Engineer

Address of the office: Rural Drinking Water & Sanitation Department,
sub- Division,
Chandra Reddy Complex
kuvempu Circle,
Bangarpet-563114

To
Jeevan Pragathi Golden International
School Nallaguttahalli (V)
Kethaganahalli(Gp) Bangarpet taluk

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies